



**WRENTHAM  
BOARD OF HEALTH  
79 South Street, Wrentham, MA. 02093  
WELL QUALITY AND QUANTITY TESTS**

The following bacteriological and chemical analyses must be performed by taking a sample *from a tap in the building* by a Massachusetts Certified Laboratory Representative:

- |   |                  |
|---|------------------|
| Total Coli Form Bacteria  | Total Hardness   |
| Ammonia Nitrogen  | Total Alkalinity |
| Nitrite Nitrogen  | Nitrate Nitrogen |
| Chloride  | Sodium           |
| Arsenic   | Lead             |
| Total Iron  | Manganese        |
| Color   | Turbidity        |
| Odor  | pH               |
| Volatile Organic Compounds (EPA 524, 624, 501, 502, 601, OR 602)        |                  |
| Total Bacteria (a/ka Standard Plate Count or Heterotrophic Plate Count) |                  |

Quality and **Quantity** tests shall be performed by a competent pump or well drilling contractor and a well shall produce a supply for each dwelling unit served by an on-site well as follows:

Well Depth (feet)	Gallons per minutes over 4 hour duration
0-150	5-6
150-200	4
200-300	2-3
Greater than 300	1-2

\*must provide well depth with data.

**VENDORS**

The names and telephone numbers provided are for reference only. This is NOT a recommendation by the Board of Health, nor does it include ALL possible vendors in Massachusetts.

*Massachusetts Certified Laboratory*

Analytical Balance Corp	800-313-2225	Alpha Analytical Balance	508-898-9220
ETR Environmental Labs	800-344-9977	G & L Labs	617-328-3663
Premier Labs	800-334-0103	John McKinnies	508-528-1404

*Pump and/or Drilling Contractor*

Richardson Wells and Pump	508-278-5333	Crystal Pump Co.	508-528-8959
Safewell Corporation	888-450-WELL	Mark's Wells & Pumps	508-528-1741
Cool Water Pump Co.	508-883-4857	Brodeur Pump Co.	508-883-9247

***The above-referenced tests must be performed and the results must be submitted to the Board of Health for analysis and approval prior to the transfer of the property.***